



Florida Department of Transportation

CHARLIE CRIST
GOVERNOR

District Two
1109 South Marion Avenue
Mail Station 2015
Lake City, FL 32025-5874

STEPHANIE C. KOPELOUSOS
SECRETARY

May 20, 2008

To: Prospective Bidders and Plan Holders

Addendum No: 2, E2L26, Financial Project # 21070545201
Drainage improvements, excavate and install sheet pile, weir, and rubble rip-rap bed.
Install drainage pipe with flap gate and restore unpaved trail for Egans Creek Tidal
Barrier at Jasmine Street. Prequalification is required.

QUESTIONS AND ANSWERS:

Question: The bid item 0455-14-3 concrete sheet piling 10"x30" has a quantity of 808 lf. The plans only show a wall length of 87 lf. Please clarify the quantity.

Answer: *The bid item is based on pile length in LF, not wall length.*

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. A copy of this addendum must be returned with your bid.

Company Name

Date

Signature

Thanks,

Patsy Elkins, CPPB
Contracts Coordinator
Phone: 386-758-3703
Fax: 850-412-8082